

CORRIGENDUM NO:- 2
(GIRLS HOSTEL)

1. All Doors will be 35mm thick block board flush doors as per S.O.R.- 9.25.2
2. Total 20 nos. of ABC type Fire Extinguishers, 2Kg capacity to be provided. First Aid Hose Reel System to be treated as deleted.

[Handwritten Signature]
04-7-2014

Brajesh Prasad
Chief Engineer

✓