

CORRIGENDUM NO-1
(Girls Hostel)

332

1. Service window of size 6'-0" (width) X4'-6"(height) to be provided in between the Kitchen and Dining Room keeping sill level at 2'-6" and Lintel Level at 7'-0".
2. The corridor width to be provided 5'-6" instead of 4'-0" in the Hostel wing.
3. In the balcony of the Hostel, 3'-0" high 10" thick brickwork to be provided with the grill fixed above it up to roof level.
4. 2'-0" high M.S. grill to be fixed above the 7'-0" high boundary wall of the courtyard along grid no.2 as per details.
5. Ventilator of 3'-6" width and 1'-0" height to be provided over the door of the Hostel room just below the ceiling.
6. The passage width to be provided 8'-6" along grid no. 17 from E to L instead of 5'-0".
7. The collapsible gate in the front entrance to be replaced by Grill gate along grid no. 18 from E to F.
8. 8mm square bars to be replaced by 10mm square bars in the grills.

19/5/14

Pantaghe
Sr. Architect
19.5.14

5/19/05/17

19-5-2014

Cheif Engineer
BSEIDC