

CORRIGENDUM NO-1
(Model Schools)

1. *There will be no brickwork beyond 3'-0" height in the side walls of the passage connecting the main building to the toilet block in all floors. Grills to be provided above 3'-0" till roof beam.*
2. *In the extreme end of the passage(along grid no.9 in architectural working drawing), grill door of 7'-0"X8'-0" to be provided for future extension of the toilets on first and second floor.*
3. *Front Verandah on first and second floor shall have a railing made of 10" brickwork till 2'-6" and piped railing of 1'-0" height above it (as per details).*
4. *Drainage pipe of 2" dia. to be provided in all the class rooms and labs on all floors.*
5. *Two nos. drainage pipe of 4" dia. to be provided on the front Verandah (at grid D' and N along grid no. 2 in architectural working drawing) connecting all the floors up 6" above the finished ground level with bend.*
6. *On passage side (along grid no. H and J in architectural working drawing) 3 nos. of griled ventilators of 4'0" (width) X1'-0" (height) be provided in each class rooms on every floors and 6 nos. of griled ventilators of 4'0"width) x 1'-0"(height) in Library.*
7. *Ceiling height of the toilet block to be cast 1'-6" below the main floor level.*
8. *Ventilators of Size 2'-0"(width)X1'-0"(height) to be provided in each toilets.*

Handwritten signatures and dates in blue ink, including a date stamp "7/5/14" and several illegible signatures.

CORRIGENDUM NO-1
(Model Schools)

- 9. The window (W) size in the classrooms to be increased to 1500(width)X1200(height) instead of 1200X1200.
- 10. The collapsible gate provided in the front entrance to be replaced with grill gate (along grid no. 2 in architectural working drawing at ground floor).
- 11. All 8mm square bars in the grill of windows to be replaced with 10mm square bars.
- 12. R.C.C pipes NP2 class 150 mm dia (S.O.R Ref. 1701) to be provided as Soil waste pipe and Water Waste Pipe .

~~7/5/14~~

07/5/14

~~7/5/14~~
7-5-2014

**Chief Engineer
BSEIDC**

Ventilators of Size 2'-0" (width)X1'-0" (height) to be provided in each toilets.